

**Izjava o svojstvima
Declaration of performance**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011
according to Construction Products Regulation (EU) No. 305/2011

Br. / No. CPR-20-13-202

1. Jedinствена identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*
BE-PSE03-C Vanjsko napajanje sastoji se od: uređaja i dodatne opreme (vidi aneks)
Power supply equipment; consisting of: Devices and Accessories (see annex)
2. Namjena/namjene: / *Intended use/es:*
Sigurnost od požara / Fire Safety
3. Proizvođač: / *Manufacturer:*
Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna, Austrija / Austria
4. Ovlašteni predstavnik: / *Authorised representative:*
nije primjenjivo / not applicable
5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / *System/s of AVCP:*
1
6. Harmonizirani standardi: / *Harmonised Standards:*
EN 54-4:1997 / A2:2006 Sustavi za otkrivanje i dojavu požara – 4. dio: Oprema za napajanje energijom
Fire detection and fire alarm systems — Part 4: Power supply equipment
EN 12101-10:2005 / AC:2007 Održavanje dima i topline – dio 10: Opskrba energijom
Smoke and heat control systems – Part 10: Power supplies
Prijavljeno tijelo/prijavljena tijela / *Notified body/ies*
0786 VdS Schadenverhütung GmbH
0786-CPR-20874
7. Objavljena svojstva: / *Declared performance/s:*
- | Bitna obilježja | Essential Characteristics | Svojstva Performance | Usklađene tehničke specifikacije; klauzula Harmonised technical specification; Clause |
|---|---|----------------------|---|
| Učink u slučaju požara | Performance under fire conditions | Položeno Passed | EN 54-4:1997 / A2:2006; 4 – 6 |
| Pogonska pouzdanost | Operational reliability | Položeno Passed | EN 54-4:1997 / A2:2006; 4 – 8 |
| Trajnost pogonske pouzdanosti, otpornost na temperaturu | Durability of operational reliability, temperature resistance | Položeno Passed | EN 54-4:1997 / A2:2006; 9.5 |
| Trajnost pogonske pouzdanosti, otpornost na vibracije | Durability of operational reliability, vibration resistance | Položeno Passed | EN 54-4:1997 / A2:2006; 9.7 – 9.8, 9.15 |
| Trajnost pogonske pouzdanosti, električna stabilnost | Durability of operational reliability, electrical stability | Položeno Passed | EN 54-4:1997 / A2:2006; 9.9 – 9.13 |
| Trajnost pogonske pouzdanosti, otpornost na vlagu | Durability of operational reliability, humidity resistance | Položeno Passed | EN 54-4:1997 / A2:2006; 9.6, 9.14 |
8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija:
Appropriate Technical Documentation and/or Specific Technical Documentation:
B-TD-0002
Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.
Ova izjava o svojstvima je dostupna na internetu: www.schrack-seconet.com/dop / *This declaration of performance is available on the internet:*
www.schrack-seconet.com/dop

Potpisano za i u ime: / Signed for and on behalf of:

Schrack Seconet AG
1120 Beč / Vienna , Austrija / Austria
28.6.2021.



ppa.
Thomas Kern
Voditelj odjela za upravljanje proizvodima i kompetentnost
Head of Product Management and Competence Center



ppa.
Edgar Eidenberger
Voditelj odjela razvoja
Head of Development

**PRILOG
ANNEX**

Predmet izjave: / Object of the declaration:

Br. proizvoda: / Item No:	Vrsta: / Type:	Opis:	Description:
20-4000109-01	BE-PSE03-C	Jedinica za napajanje 24V/3A IP30	Power supply 24V/3A IP30
20-4000111-01	BE-PSU03-OF	Jedinica za napajanje 24V/3A	Power supply 24V/3A
20-4000113-01	BE-FIB05-C	Osnovna pločica osigurač	Fuse module
20-4000120-01	BE-MAKKU	Mjerni adapter	Measurement adapter