

**IZJAVA O SVOJSTVIMA  
DECLARATION OF PERFORMANCE**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011  
according to Construction Products Regulation (EU) No 305/2011

**Br. / No. CPR-20-13-018**

1. Jedinствена identifikacijska oznaka vrste proizvoda: / Unique identification code of the product-type:

**BM-BSI** Ulazno/izlazni modul (vidi aneks)  
Input/Output module (see annex)

2. Namjena/namjene: / Intended use/es:

**sigurnost od požara / Fire safety**

3. Proizvođač: / Manufacturer:

**Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Wien / Vienna, Österreich / Austria**

4. Ovlašteni predstavnik: / Authorised representative:

**nije primjenjivo / not applicable**

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / System/s of AVCP:

**1**

6a. Usklađena norma: / Harmonised standard:

**EN 54-18:2005/AC:2007** Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/izlazni uređaji  
Fire detection and fire alarm systems — Part 18: Input/output devices

Prijavljeno tijelo/prijavljena tijela: / Notified body/ies:

**0786 VdS Schadenverhütung GmbH**

7. Objavljena svojstva: / Declared performance/s:

Bitna obilježja		svojstva	Usklađene tehničke specifikacije; klauzula
	<i>Essential characteristics</i>	<i>Performance</i>	<i>Harmonised technical specification; Clause</i>
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-18:2005/AC:2007; 5.2
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-18:2005/AC:2007; 5.1.4
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-18:2005/AC:2007; 5.1.4
Trajnost pogonske pouzdanosti, otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-18:2005/AC:2007; 5.3 – 5.4
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-18:2005/AC:2007; 5.8 – 5.11
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	položeno pass	EN 54-18:2005/AC:2007; 5.5 – 5.6
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-18:2005/AC:2007; 5.7
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-18:2005/AC:2007; 5.2, 5.12

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija: /  
Appropriate Technical Documentation and/or Specific Technical Documentation:

**B-TD-BM-BSI-TMI-MCP1**

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima.

Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača. /

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Ova izjava o svojstvima je dostupna na internetu: / This declaration of performance is available on the internet:

[www.Schrack-Seconet.com/DoP](http://www.Schrack-Seconet.com/DoP)

Za proizvođača i u njegovo ime potpisao: / Signed for and on behalf by:


**Schrack Seconet AG**  
1120 Wien / Vienna, Österreich / Austria, 15.01.2018

ppa.



Thomas Kern  
Voditelj odjela za upravljanje proizvodima i kompetentnost  
Head of Product Management and Competence Center

ppa.



Heinrich Kohlenberger  
Voditelj odjela razvoja  
Head of Development

**Prilog  
Annex**

---

Predmet izjave: / Object of the declaration:

Broj artikla: / Item No:	Vrsta: / Type:	Opis:	Description:
20-2600000-01	BM-BSI	Ulazno/izlazni uređaj	Input/Output device