

**IZJAVA O SVOJSTVIMA
DECLARATION OF PERFORMANCE**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011
according to Construction Products Regulation (EU) No 305/2011

Br. / No. CPR-20-13-007

1. Jedinstvena identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*

BX-IM4 Ulazno/izlazni modul (vidi aneks)
Input/Output module (see annex)

2. Namjena/namjene: / *Intended use/es:*

sigurnost od požara / Fire safety

3. Proizvođač: / *Manufacturer:*

Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Wien / Vienna, Österreich / Austria

4. Ovlašteni predstavnik: / *Authorised representative:*

nije primjenjivo / not applicable

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP)v: / *System/s of AVCP:*

1

6a. Usklađena norma: / *Harmonised standard:*

EN 54-17:2005/AC:2007 Sustavi za otkrivanje i dojavu požara – 17. dio: Izolatori kratkoga spoja
Fire detection and fire alarm systems — Part 17: Short-circuit isolators

EN 54-18:2005/AC:2007 Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/izlazni uređaji
Fire detection and fire alarm systems — Part 18: Input/output devices

Prijavljeno tijelo/prijavljena tijela: / *Notified body/ies:*

0786 Vds Schadenverhütung GmbH

7. Objavljena svojstva: / *Declared performance/s:*

| Bitna obilježja | Essential characteristics | svojstva | Usklađene tehničke specifikacije; klauzula |
|---|---|---------------|--|
| | | Performance | Harmonised technical specification; Clause |
| Učink u slučaju požara | Performance under fire conditions | položeno pass | EN 54-17:2005 / AC:2007; 5.2 |
| Pogonska pouzdanost | Operational reliability | položeno pass | EN 54-17:2005 / AC:2007; 4 |
| Trajnost pogonske pouzdanosti, otpornost na temperaturu | Durability of operational reliability, temperature resistance | položeno pass | EN 54-17:2005 / AC:2007; 5.4 – 5.5 |
| Trajnost pogonske pouzdanosti, otpornost na vibracije | Durability of operational reliability, vibration resistance | položeno pass | EN 54-17:2005 / AC:2007; 5.9 – 5.12 |
| Trajnost pogonske pouzdanosti, otpornost na vlagu | Durability of operational reliability, humidity resistance | položeno pass | EN 54-17:2005 / AC:2007; 5.6 – 5.7 |
| Trajnost pogonske pouzdanosti, otpornost na koroziju | Durability of operational reliability, corrosion resistance | položeno pass | EN 54-17:2005 / AC:2007; 5.8 |
| Trajnost pogonske pouzdanosti, električna stabilnost | Durability of operational reliability, electrical stability | položeno pass | EN 54-17:2005 / AC:2007; 5.3, 5.13 |
| Odgoda aktivacije (vrijeme aktivacije pri alarmu) | Response delay (response time) | položeno pass | EN 54-18:2005 / AC:2007; 5.2 |
| Učink u slučaju požara | Performance under fire conditions | položeno pass | EN 54-18:2005 / AC:2007; 5.1.4 |
| Pogonska pouzdanost | Operational reliability | položeno pass | EN 54-18:2005 / AC:2007; 5.1.4 |
| Trajnost pogonske pouzdanosti, otpornost na temperaturu | Durability of operational reliability, temperature resistance | položeno pass | EN 54-18:2005 / AC:2007; 5.3 – 5.4 |
| Trajnost pogonske pouzdanosti, otpornost na vibracije | Durability of operational reliability, vibration resistance | položeno pass | EN 54-18:2005 / AC:2007; 5.8 – 5.11 |
| Trajnost pogonske pouzdanosti, otpornost na vlagu | Durability of operational reliability, humidity resistance | položeno pass | EN 54-18:2005 / AC:2007; 5.5 – 5.6 |
| Trajnost pogonske pouzdanosti, otpornost na koroziju | Durability of operational reliability, corrosion resistance | položeno pass | EN 54-18:2005 / AC:2007; 5.7 |
| Trajnost pogonske pouzdanosti, električna stabilnost | Durability of operational reliability, electrical stability | položeno pass | EN 54-18:2005 / AC:2007; 5.2, 5.12 |

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija: /
Appropriate Technical Documentation and/or Specific Technical Documentation:

B-HB-0081

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima.

Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača. /

The performance of the product identified above is in conformity with the set of declared performance/s.


This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Ova izjava o svojstvima je dostupna na internetu: / *This declaration of performance is available on the internet:*
www.Schrack-Seconet.com/DoP

Za proizvođača i u njegovo ime potpisao: / *Signed for and on behalf by:*


Schrack Seconet AG
1120 Wien / Vienna, Österreich / Austria, 15.01.2018

ppa.



Thomas Kern
Voditelj odjela za upravljanje proizvodima i kompetentnost
Head of Product Management and Competence Center

ppa.



Heinrich Kohlerberger
Voditelj odjela razvoja
Head of Development

**Prilog
Annex**

Predmet izjave: / Object of the declaration:

| Broj artikla: / Item No: | Vrsta: / Type: | Opis: | Description: |
|---------------------------------|-----------------------|---------------|---------------------|
| 20-2100003-01 | BX-IM4 | Ulazni modul | Input module |
| FG020234 | GEH MOD IP66 | IP 66 ormarić | IP 66 cabinet |
| 20-2101000-01 | TK PC 99-6-M | IP 66 ormarić | IP 66 cabinet |