

IZJAVA O SVOJSTVIMA
DECLARATION OF PERFORMANCE

prema Uredbi o građevnim proizvodima (EU) br. 305/2011
according to Construction Products Regulation (EU) No 305/2011

Br. / No. CPR-20-13-103

1. Jedinstvena identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*

BX-API Alarmni uređaj, zvučni (vidi aneks)
Alarm device, acoustical (see annex)

2. Namjena/namjene: / *Intended use/es:*

sigurnost od požara / Fire safety

3. Proizvođač: / *Manufacturer:*

Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Wien / Vienna, Österreich / Austria

4. Ovlašteni predstavnik: / *Authorised representative:*

nije primjenjivo / not applicable

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / *System/s of AVCP:*

1

6a. Usklađena norma: / *Harmonised standard:*

EN 54-3:2001/A2:2006 Sustavi za otkrivanje i dojavu požara – 3. dio: Naprave za uzbuđivanje – Sirene
Fire detection and fire alarm systems — Part 3: Fire alarm devices — Sounders

Prijavljeno tijelo/prijavljena tijela: / *Notified body/ies:*

0786 VdS Schadenverhütung GmbH

7. Objavljena svojstva: / *Declared performance/s:*

Bitna obilježja	Essential characteristics	svojstva	Usklađene tehničke specifikacije; klauzula
		Performance	Harmonised technical specification; Clause
Učinkak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-3:2001/A2:2006; 4.2 – 4.3, 4.4.1 – 4.4.2, 5.2 – 5.3, 5.18 – 5.20
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-3:2001/A2:2006; 4.4 – 4.6, 5.4
Trajnost pogonske pouzdanosti, otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-3:2001/A2:2006; 5.5 – 5.9
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	položeno pass	EN 54-3:2001/A2:2006; 5.8 – 5.10
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-3:2001/A2:2006; 5.11
Trajnost pogonske pouzdanosti, otpornost udarce i vibracije	Durability of operational reliability, shock and vibration resistance	položeno pass	EN 54-3:2001/A2:2006; 5.12 – 5.15
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-3:2001/A2:2006; 5.16
Trajnost pogonske pouzdanosti, otpornost ulaza	Durability of operational reliability, resistance to ingress	položeno pass	EN 54-3:2001/A2:2006; 5.17

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija: / *Appropriate Technical Documentation and/or Specific Technical Documentation:*

B-HB-0081

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima.

Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača. / *The performance of the product identified above is in conformity with the set of declared performance/s.*

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.


Ova izjava o svojstvima je dostupna na internetu: / *This declaration of performance is available on the internet:*

www.Schrack-Seconet.com/DoP

Za proizvođača i u njegovo ime potpisao: / Signed for and on behalf by:


Schrack Seconet AG
1120 Wien / Vienna, Österreich / Austria, 15.01.2018

ppa.



Thomas Kern
Voditelj odjela za upravljanje proizvodima i kompetentnost
Head of Product Management and Competence Center

ppa.



Heinrich Kohlenberger
Voditelj odjela razvoja
Head of Development

**Prilog
Annex**

Predmet izjave: / Object of the declaration:

Broj artikla: / Item No:	Vrsta: / Type:	Opis:	Description:
20-2100010-01	BX-API	Unutarnja sirena	Base siren