

**Izvaja o svojstvima  
Declaration of performance**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011  
according to Construction Products Regulation (EU) No. 305/2011

**Br. / No. CPR-20-20-205**

1. Jedinствена identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*  
**BE-PSE02** Vanjsko napajanje sastoji se od: uređaja i dodatne opreme (vidi aneks)  
**BE-PSE02-IOM** *Power supply equipment; consisting of: Devices and Accessories (see annex)*
2. Namjena/namjene: / *Intended use/es:*  
**Sigurnost od požara / Fire Safety**
3. Proizvođač: / *Manufacturer:*  
**Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna, Austrija / Austria**
4. Ovlašteni predstavnik: / *Authorised representative:*  
**nije primjenjivo / not applicable**
5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / *System/s of AVCP:*  
**1**
6. Harmonizirani standardi: / *Harmonised Standards:*  
**EN 54-4:1997 / A2:2006** Sustavi za otkrivanje i dojavu požara – 4. dio: Oprema za napajanje energijom  
*Fire detection and fire alarm systems — Part 4: Power supply equipment*  
**EN 54-17:2005 / AC:2007** Sustavi za otkrivanje i dojavu požara – 17. dio: Izolatori kratkoga spoja  
*Fire detection and fire alarm systems — Part 17: Short-circuit isolators*  
**EN 54-18:2005 / AC:2007** Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/izlazni uređaji  
*Fire detection and fire alarm systems — Part 18: Input/output devices*  
Prijavljeno tijelo/prijavljena tijela / *Notified body/ies*  
**0786 VdS Schadenverhütung GmbH**  
**0786-CPR-21684**
7. Objavljena svojstva: / *Declared performance/s:*

Bitna obilježja	Essential Characteristics	Svojstva Performance	Usklađene tehničke specifikacije; klauzula Harmonised technical specification; Clause
Učinak u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-4:1997 / A2:2006; 4 – 6
Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-4:1997 / A2:2006; 4 – 8
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-4:1997 / A2:2006; 9.5
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-4:1997 / A2:2006; 9.7 – 9.8, 9.15
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-4:1997 / A2:2006; 9.9 – 9.13
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-4:1997 / A2:2006; 9.6, 9.14
Učinak u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-17:2005 / AC:2007; 5.2
Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-17:2005 / AC:2007; 4
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	NPD NPD	EN 54-17:2005 / AC:2007; 5.4
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-17:2005 / AC:2007; 5.5
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	NPD NPD	EN 54-17:2005 / AC:2007; 5.9 – 5.10
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-17:2005 / AC:2007; 5.11 – 5.12
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-17:2005 / AC:2007; 5.6 – 5.7
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	NPD NPD	EN 54-17:2005 / AC:2007; 5.8
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-17:2005 / AC:2007; 5.3, 5.13

Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	Položeno Passed	EN 54-18:2005 / AC:2007; 5.2
Učinak u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-18:2005 / AC:2007; 5.1.4
Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-18:2005 / AC:2007; 5.1.4
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	NPD NPD	EN 54-18:2005 / AC:2007; 5.3
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-18:2005 / AC:2007; 5.4
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-18:2005 / AC:2007; 5.8 – 5.11
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-18:2005 / AC:2007; 5.5 – 5.6
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	NPD NPD	EN 54-18:2005 / AC:2007; 5.7
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-18:2005 / AC:2007; 5.2, 5.12

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija:  
*Appropriate Technical Documentation and/or Specific Technical Documentation:*

**B-TD-0007**

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.  
*The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.*

Ova izjava o svojstvima je dostupna na internetu: [www.schrack-seconet.com/dop](http://www.schrack-seconet.com/dop) / *This declaration of performance is available on the internet:*

[www.schrack-seconet.com/dop](http://www.schrack-seconet.com/dop)

Potpisano za i u ime: / *Signed for and on behalf of:*

**Schrack Seconet AG**  
1120 Beč / Vienna, Austrija / Austria  
20.7.2020.



ppa.  
Thomas Kern  
Voditelj odjela za upravljanje proizvodima i kompetentnost  
*Head of Product Management and Competence Center*



ppa.  
Edgar Eidenberger  
Voditelj odjela razvoja  
*Head of Development*

**PRILOG  
ANNEX**

Predmet izjave: / Object of the declaration:

<b>Br. proizvoda: / Item No:</b>	<b>Vrsta: / Type:</b>	<b>Opis:</b>	<b>Description:</b>
20-4000125-01	BE-PSE02	Jedinica za napajanje 24V/1A IP30	Power supply 24V/1A IP30
20-4000125-02	BE-PSE02-IOM	Jedinica za napajanje 24V/1A IP30 IOM	Power supply 24V/1A IP30 IOM