



## Izjava o svojstvima Declaration of Performance

CPR-20-17-021-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:

**BX-WGW**

2. Namjena/namjene / Intended use/es:

**Izlazni/ulazni uređaji za sustave dojave požara**

**In-/Output device for fire detection and fire alarm systems**

3. Proizvođač / Manufacturer

**Schrack Seconet AG, Eibesbrunnnergasse 18, 1120 Beč / Vienna**

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance

**1**

6. Usklađena norma / Harmonised standard(s):

**EN 54-17:2005 + AC:2007**

**EN 54-18:2005 + AC:2007**

**EN 54-25:2008 + AC:2012**

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

**0786**

**VdS Schadenverhütung GmbH**

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-17:2005 +AC:2007	5.2
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-17:2005 +AC:2007	4
Trajnost pogonske pouzdanosti otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-17:2005 +AC:2007	5.4 – 5.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-17:2005 +AC:2007	5.9 – 5.12
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-17:2005 +AC:2007	5.6 – 5.7
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-17:2005 +AC:2007	5.8
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-17:2005 +AC:2007	5.3, 5.13
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-18:2005 +AC:2007	5.2

SCHRACK SECONET AG • Eibesbrunnnergasse 18 • A-1120 Wien  
UniCredit Bank Austria AG • Konto-Nr. 09493 191 200 • BLZ 12000 • IBAN AT96 1100 0094 9319 1200 • BIC BKAUATWW  
FN 123356g Handelsgericht Wien • ARA 9588 • DVR 0785083 • UID ATU 37395207

GESCHÄFTSSTELLEN WIEN, NIEDERÖSTERREICH und BURGENLAND: Eibesbrunnnergasse 18, A-1120 Wien, Tel.: +43-1-811 57-0\*, Fax: +43-1-811 57-222  
KUNDENDIENST WIEN, Tel.: +43-1-811 03-0\*, Fax: +43-1-811 57-500

OBERÖSTERREICH: Kornstraße 16, A-4060 Leonding-Hart, Tel. +43-732-677 900-0\*, Fax: +43-732-677 900-20, SALZBURG: Vogelweidenstraße 44a, A-5020 Salzburg, Tel.: +43-662-887 122-0\*, Fax: +43-662-887 122-73,  
TIROL: Dr. Franz Werner-Straße 36, A-6020 Innsbruck, Tel. +43-512-365 366-0\*, Fax: +43-512-365 366-30, VORARLBERG: Sebastiansstraße 13a, A-6850 Dornbirn, Tel. +43-5572-511 99-0\*, Fax: +43-5572-511 99-30,  
STEIERMARK: Neuseiersberger Straße 157, A-8055 Graz, Tel. +43-316-407 676-0\*, Fax: +43-316-407 676-35, KÄRNTEN: Finkkirchner Straße 138, A-9020 Klagenfurt, Tel. +43-463-429 362-0\*, Fax: +43-463-429 362-25

Ein Unternehmen der Securitas Gruppe Schweiz

Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-18:2005 +AC:2007	5.1.4
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-18:2005 +AC:2007	5.1.4
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-18:2005 +AC:2007	5.3 – 5.4
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-18:2005 +AC:2007	5.8 – 5.11
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-18:2005 +AC:2007	5.5 – 5.6
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-18:2005 +AC:2007	5.7
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-18:2005 +AC:2007	5.2, 5.12
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-25:2008 +AC:2012	4.1, 4.2.2, 5.2, 8.3.7
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-25:2008 +AC:2012	8.2.3, 8.2.6
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-25:2008 +AC:2012	4.2.1, 4.2.3 – 4.2.7, 5.3 – 5.4, 6 – 7, 8.2.2, 8.2.4 – 8.2.5, 8.2.7 – 8.2.9, 8.3.1 – 8.3.6
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-25:2008 +AC:2012	8.3.9 – 8.3.11
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-25:2008 +AC:2012	8.3.16 – 8.3.19
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-25:2008 +AC:2012	8.3.12 – 8.3.14
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-25:2008 +AC:2012	8.3.15
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-25:2008 +AC:2012	8.3.20

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.  
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna

05.05.2017

ppa.




Thomas Kern  
Voditelj Odjela za upravljanje proizvodom  
i centra kompetencije /  
Head of Product Management  
and Competence Center

ppa.



Heinz Kohlenberger  
Voditelj razvojnog odjela /  
Head of Development

	<p><b>NAPOMENA</b> Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete. Za točnu instalaciju i rukovanje pogledajte upute za instalaciju <a href="https://www.schrack-seconet.com/de/services/downloadcenter">https://www.schrack-seconet.com/de/services/downloadcenter</a> → B-HB-070 Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se..</p>
---	---

	<p><b>NOTE</b> Improper use or installation of the device can lead to injury or damages. For the exact procedure for proper installation and handling, please refer to the manufacturer documentation: <a href="https://www.schrack-seconet.com/en/services/downloadcenter">https://www.schrack-seconet.com/en/services/downloadcenter</a> → B-HB-070 Please read this document carefully and follow the safety instructions before you begin with the installation.</p>
---	--