

**IZJAVA O SVOJSTVIMA
DECLARATION OF PERFORMANCE**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011
according to Construction Products Regulation (EU) No 305/2011

Br. / No. CPR-20-13-010

1. Jedinствена identifikacijska oznaka vrste proizvoda: / Unique identification code of the product-type:

BX-RGW

Ulazno/Izlazni modul za tehnologiju bežičnog prijenosa (vidi aneks)
Input/Output module Radio transmission technology (see annex)

2. Namjena/namjene: / Intended use/es:

sigurnost od požara / Fire safety

3. Proizvođač: / Manufacturer:

Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Wien / Vienna, Österreich / Austria

4. Ovlašteni predstavnik: / Authorised representative:

nije primjenjivo / not applicable

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / System/s of AVCP:

1

6a. Usklađena norma: / Harmonised standard:

EN 54-17:2005/AC:2007

Sustavi za otkrivanje i dojavu požara – 17. dio: Izolatori kratkoga spoja
Fire detection and fire alarm systems — Part 17: Short-circuit isolators

EN 54-18:2005/AC:2007

Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/izlazni uređaji
Fire detection and fire alarm systems — Part 18: Input/output devices

EN 54-25:2008/AC:2012

Sustavi za otkrivanje i dojavu požara – 25. dio: Dijelovi koje upotrebljavaju radio veze
Fire detection and fire alarm systems — Part 25: Components using radio links

Prijavljeno tijelo/prijavljena tijela: / Notified body/ies:

0786 VdS Schadenverhütung GmbH

7. Objavljena svojstva: / Declared performance/s:

Bitna obilježja	Essential characteristics	svojstva Performance	Usklađene tehničke specifikacije; klauzula Harmonised technical specification; Clause
Učink u slučaju požara	Performance under fire conditions	položeno pass	EN 54-17:2005/AC:2007; 5.2
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-17:2005/AC:2007; 4
Trajnost pogonske pouzdanosti, otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-17:2005/AC:2007; 5.4 – 5.5
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-17:2005/AC:2007; 5.9 – 5.12
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	položeno pass	EN 54-17:2005/AC:2007; 5.6 – 5.7
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-17:2005/AC:2007; 5.8
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-17:2005/AC:2007; 5.3, 5.13
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-18:2005/AC:2007; 5.2
Učink u slučaju požara	Performance under fire conditions	položeno pass	EN 54-18:2005/AC:2007; 5.1.4
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-18:2005/AC:2007; 5.1.4
Trajnost pogonske pouzdanosti, otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-18:2005/AC:2007; 5.3 – 5.4
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-18:2005/AC:2007; 5.8 – 5.11
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	položeno pass	EN 54-18:2005/AC:2007; 5.5 – 5.6
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-18:2005/AC:2007; 5.7
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-18:2005/AC:2007; 5.2, 5.12

Bitna obilježja	Essential characteristics	svojstva Performance	Usklađene tehničke specifikacije; klauzula Harmonised technical specification; Clause
Učinak u slučaju požara	Performance under fire conditions	položeno pass	EN 54-25:2008/AC:2012; 4.1, 4.2.2, 5.2, 8.3.7
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-25:2008/AC:2012; 8.2.3, 8.2.6
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-25:2008/AC:2012; 4.2.1, 4.2.3 – 4.2.7, 5.3 – 5.4, 6 – 7, 8.2.2, 8.2.4 – 8.2.5, 8.2.7 – 8.2.9, 8.3.1 – 8.3.6
Trajnost pogonske pouzdanosti, otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-25:2008/AC:2012; 8.3.9 – 8.3.11
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-25:2008/AC:2012; 8.3.16 – 8.3.19
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	položeno pass	EN 54-25:2008/AC:2012; 8.3.12 – 8.3.14
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-25:2008/AC:2012; 8.3.15
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-25:2008/AC:2012; 8.3.20

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija: /
Appropriate Technical Documentation and/or Specific Technical Documentation:

B-HB-0081

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima.

Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača. /

The performance of the product identified above is in conformity with the set of declared performance/s.


This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Ova izjava o svojstvima je dostupna na internetu: / This declaration of performance is available on the internet:
www.Schrack-Seconet.com/DoP

Za proizvođača i u njegovo ime potpisao: / Signed for and on behalf by:

Schrack Seconet AG
1120 Wien / Vienna, Österreich / Austria, 15.01.2018

ppa.



Thomas Kern
Voditelj odjela za upravljanje proizvodima i kompetentnost
Head of Product Management and Competence Center

ppa.



Heinrich Kohleberger
Voditelj odjela razvoja
Head of Development

**Prilog
Annex**

Predmet izjave: / Object of the declaration:

Broj artikla: / Item No: 20-2100006-01	Vrsta: / Type: BX-RGW	Opis: Ulazno/izlazni modul	Description: Input/Output module
--	---------------------------------	--------------------------------------	--