

**IZVAJA O SVOJSTVIMA  
DECLARATION OF PERFORMANCE**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011  
according to Construction Products Regulation (EU) No. 305/2011

**Br. / No. CPR-20-13-010**

1. Jedinstvena identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*  
**BX-RGW** Ulazno/Izlazni modul za tehnologiju bežičnog prijenosa (vidi aneks)  
*Input/Output module Radio transmission technology (see annex)*
2. Namjena/namjene: / *Intended use/es:*  
**Sigurnost od požara / Fire Safety**
3. Proizvođač: / *Manufacturer:*  
**Schrack Seconet AG, Eibesbrunnnergasse 18, 1120 Beč / Vienna, Austrija / Austria**
4. Ovlašteni predstavnik: / *Authorised representative:*  
**nije primjenjivo / not applicable**
5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / *System/s of AVCP:*  
**1**
6. Harmonizirani standardi: / *Harmonised Standards:*  
**EN 54-17:2005 / AC:2007** Sustavi za otkrivanje i dojavu požara – 17. dio: Izolatori kratkoga spoja  
*Fire detection and fire alarm systems — Part 17: Short-circuit isolators*  
**EN 54-18:2005 / AC:2007** Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/Izlazni uređaji  
*Fire detection and fire alarm systems — Part 18: Input/output devices*  
**EN 54-25:2008 / AC:2012** Sustavi za otkrivanje i dojavu požara – 25. dio: Dijelovi koje upotrebljavaju radio veze  
*Fire detection and fire alarm systems — Part 25: Components using radio links*  
  
Prijavljeno tijelo/prijavljena tijela / *Notified body/ies*  
**0786 VdS Schadenverhütung GmbH**  
**0786-CPD-21209**
7. Objavljena svojstva: / *Declared performance/s:*

Bitna obilježja	Essential Characteristics	Svojstva Performance	Usklađene tehničke specifikacije; klauzula Harmonised technical specification; Clause
Učink u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-17:2005 / AC:2007, 5.2
Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-17:2005 / AC:2007, 4
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-17:2005 / AC:2007, 5.4 – 5.5
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-17:2005 / AC:2007, 5.9 – 5.12
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-17:2005 / AC:2007, 5.6 – 5.7
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	Položeno Passed	EN 54-17:2005 / AC:2007, 5.8
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-17:2005 / AC:2007, 5.3, 5.13
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	Položeno Passed	EN 54-18:2005 / AC:2007, 5.2
Učink u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-18:2005 / AC:2007, 5.1.4
Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-18:2005 / AC:2007, 5.1.4
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-18:2005 / AC:2007, 5.3 – 5.4
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-18:2005 / AC:2007, 5.8 – 5.11
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-18:2005 / AC:2007, 5.5 – 5.6
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	Položeno Passed	EN 54-18:2005 / AC:2007, 5.7
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-18:2005 / AC:2007, 5.2, 5.12
Učink u slučaju požara	Performance under fire conditions	Položeno Passed	EN 54-25:2008 / AC:2012, 4.1, 4.2.2, 5.2, 8.3.7
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	Položeno Passed	EN 54-25:2008 / AC:2012, 8.2.3, 8.2.6

Pogonska pouzdanost	Operational reliability	Položeno Passed	EN 54-25:2008 / AC:2012: 4.2.1, 4.2.3 – 4.2.7, 5.3 – 5.4, 6 – 7, 8.2.2, 8.2.4 – 8.2.5, 8.2.7 – 8.2.9, 8.3.1 – 8.3.6
Trajnost pogonske pouzdanosti, otpornost na temperature	Durability of operational reliability, temperature resistance	Položeno Passed	EN 54-25:2008 / AC:2012: 8.3.9 – 8.3.11
Trajnost pogonske pouzdanosti, otpornost na vibracije	Durability of operational reliability, vibration resistance	Položeno Passed	EN 54-25:2008 / AC:2012: 8.3.16 – 8.3.19
Trajnost pogonske pouzdanosti, otpornost na vlagu	Durability of operational reliability, humidity resistance	Položeno Passed	EN 54-25:2008 / AC:2012: 8.3.12 – 8.3.14
Trajnost pogonske pouzdanosti, otpornost na koroziju	Durability of operational reliability, corrosion resistance	Položeno Passed	EN 54-25:2008 / AC:2012: 8.3.15
Trajnost pogonske pouzdanosti, električna stabilnost	Durability of operational reliability, electrical stability	Položeno Passed	EN 54-25:2008 / AC:2012: 8.3.20

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija:  
*Appropriate Technical Documentation and/or Specific Technical Documentation:*  
**B-HB-0035**

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.  
*The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.*

Ova izjava o svojstvima je dostupna na internetu: [www.schrack-seconet.com/dop](http://www.schrack-seconet.com/dop) / *This declaration of performance is available on the internet: www.schrack-seconet.com/dop*

Potpisano za i u ime: / *Signed for and on behalf of:*

**Schrack Seconet AG**  
1120 Beč / Vienna, Austrija / Austria  
19.11.2019.

ppa.  
Thomas Ham  
Voditelj odjela za upravljanje proizvodima i kompetentnost  
*Head of Product Management and Competence Center*

ppa.  
Edgar Eidenberger  
Voditelj odjela razvoja  
*Head of Development*

**PRILOG  
ANNEX**

---

**Predmet izjave / Object of the declaration:**

<b>Br. proizvoda: / Item No:</b>	<b>Vrsta: / Type:</b>	<b>Opis:</b>	<b>Description:</b>
20-2100006-01	BX-RGW	BX- RGW Radio pristupnika	BX-RGW Radiogateway