



Izjava o svojstvima Declaration of Performance

CPR-20-13-012-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:

BX-O2I4

2. Namjena/namjene / Intended use/es:

Izlazni/ulazni uređaji za sustave dojave požara

In-/Output device for fire detection and fire alarm systems

3. Proizvođač / Manufacturer

Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance

1

6. Usklađena norma / Harmonised standard(s):

EN 54-17:2005 + AC:2007

EN 54-18:2005 + AC:2007

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

0786

VdS Schadenverhütung GmbH

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učink u slučaju požara	Performance under fire conditions	položeno pass	EN 54-17:2005 +AC:2007	5.2
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-17:2005 +AC:2007	4
Trajnost pogonske pouzdanosti otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-17:2005 +AC:2007	5.4 – 5.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-17:2005 +AC:2007	5.9 – 5.12
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-17:2005 +AC:2007	5.6 – 5.7
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-17:2005 +AC:2007	5.8
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-17:2005 +AC:2007	5.3, 5.13
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-18:2005 +AC:2007	5.2
Učink u slučaju požara	Performance under fire conditions	položeno	EN 54-18:2005 +AC:2007	5.1.4

		pass		
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-18:2005 +AC:2007	5.1.4
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-18:2005 +AC:2007	5.3 – 5.4
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-18:2005 +AC:2007	5.8 – 5.11
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-18:2005 +AC:2007	5.5 – 5.6
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-18:2005 +AC:2007	5.7
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-18:2005 +AC:2007	5.2, 5.12

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna

27.04.2017

ppa.

Thomas Kern
Voditelj Odjela za upravljanje proizvodom
i centra kompetencije /
Head of Product Management
and Competence Center

ppa.

Heinz Kohlenberger
Voditelj razvojnog odjela /
Head of Development



NAPOMENA

Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete.
Za točnu instalaciju i rukovanje pogledajte upute za instalaciju
<https://www.schrack-seconet.com/de/services/downloadcenter> → B-HB-070
Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se..



NOTE

Improper use or installation of the device can lead to injury or damages.
For the exact procedure for proper installation and handling, please refer to the manufacturer documentation:
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-HB-070
Please read this document carefully and follow the safety instructions before you begin with the installation.