



## Izjava o svojstvima Declaration of Performance

CPR-20-13-014-HR-EN

1. Jedinstvena identifikacijska oznaka vrste proizvoda / Unique identification code of the product-type:

**BX-I2**

2. Namjena/namjene / Intended use/es:

**Izlazni/ulazni uređaji za sustave dojave požara**

**In-/Output device for fire detection and fire alarm systems**

3. Proizvođač / Manufacturer

**Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Beč / Vienna**

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP) / System/s of assessment and verification of constancy of performance

**1**

6. Usklađena norma / Harmonised standard(s):

**EN 54-17:2005 + AC:2007**

**EN 54-18:2005 + AC:2007**

Prijavljeno tijelo/prijavljena tijela / Notified Body/ies:

**0786**

**VdS Schadenverhütung GmbH**

7. Objavljena svojstva / Declared performance/s

Bitna obilježja	Essential characteristics	Svojstvima Performance	Harmonizacija tehničke specifikacije Harmonised technical specification	Odjeljak Clause
Učink u slučaju požara	Performance under fire conditions	položeno pass	EN 54-17:2005 +AC:2007	5.2
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-17:2005 +AC:2007	4
Trajnost pogonske pouzdanosti otpornost na temperaturu	Durability of operational reliability, temperature resistance	položeno pass	EN 54-17:2005 +AC:2007	5.4 – 5.5
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-17:2005 +AC:2007	5.9 – 5.12
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-17:2005 +AC:2007	5.6 – 5.7
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-17:2005 +AC:2007	5.8
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-17:2005 +AC:2007	5.3, 5.13
Odgoda aktivacije (vrijeme aktivacije pri alarmu)	Response delay (response time to fire)	položeno pass	EN 54-18:2005 +AC:2007	5.2
Učink u slučaju požara	Performance under fire conditions	položeno	EN 54-18:2005 +AC:2007	5.1.4

SCHRACK SECONET AG • Eibesbrunnergasse 18 • A-1120 Wien

UniCredit Bank Austria AG • Konto-Nr. 09493 191 200 • BLZ 12000 • IBAN AT96 1100 0094 9319 1200 • BIC BKAUATWW  
FN 123356g Handelsgericht Wien • ARA 9588 • DVR 0785083 • UID ATU 37395207

GESCHÄFTSSTELLEN: WIEN, NIEDERÖSTERREICH und BURGENLAND: Eibesbrunnergasse 18, A-1120 Wien, Tel.: +43-1-811 57-0\*, Fax: +43-1-811 57-222

KUNDENDIENST WIEN: Tel.: +43-1-811 03-0\*, Fax: +43-1-811 57-500.

ÖBERÖSTERREICH: Kornstraße 16, A-4060 Leonding Hart, Tel.: +43-732-677 900-0\*, Fax: +43-732-677 900 20, SALZBURG: Vogelweiderstraße 44a, A-5020 Salzburg, Tel.: +43-662-887 122-0\*, Fax: +43-662-887 122-73,  
TIROL: Dr. Franz-Werner Straße 36, A-6020 Innsbruck, Tel.: +43-512-365 366 0\*, Fax: +43-512-365 366 30, VORARLBERG: Sebastianstraße 13a, A-6850 Dornbirn, Tel.: +43-5572-511 99 0\*, Fax: +43-5572-511 99-30,  
STEIERMARK: Neupörsberger Straße 157, A-8055 Graz, Tel.: +43-316-407 676 0\*, Fax: +43-316-407 676 35, KÄRNTEN: Feldkirchner Straße 138, A-9020 Klagenfurt, Tel.: +43-463-429 362 0\*, Fax: +43-463-429 362-25

Ein Unternehmen der Securitas Gruppe Schweiz

		pass		
Pogonska pouzdanost	Operational reliability	položeno pass	EN 54-18:2005 +AC:2007	5.1.4
Trajnost pogonske pouzdanosti otpornost na temperature	Durability of operational reliability, temperature resistance	položeno pass	EN 54-18:2005 +AC:2007	5.3 – 5.4
Trajnost pogonske pouzdanosti otpornost na vibracije	Durability of operational reliability, vibration resistance	položeno pass	EN 54-18:2005 +AC:2007	5.8 – 5.11
Trajnost pogonske pouzdanosti otpornost na vlagu u zraku	Durability of operational reliability, humidity resistance	položeno pass	EN 54-18:2005 +AC:2007	5.5 – 5.6
Trajnost pogonske pouzdanosti otpornost na koroziju	Durability of operational reliability, corrosion resistance	položeno pass	EN 54-18:2005 +AC:2007	5.7
Trajnost pogonske pouzdanosti električna stabilnost	Durability of operational reliability, electrical stability	položeno pass	EN 54-18:2005 +AC:2007	5.2, 5.12

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima. Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača.  
The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Za proizvođača i u njegovo ime potpisao / Signed for and on behalf of the manufacturer by:

Schrack Seconet AG

Beč / Vienna


05.05.2017

ppa.



Thomas Kern  
Voditelj Odjela za upravljanje proizvodom  
i centra kompetencije /  
Head of Product Management  
and Competence Center

ppa.



Heinz Kohlenberger  
Voditelj razvojnog odjela /  
Head of Development



**NAPOMENA**

Neispravna uporaba ili instalacija uređaja može uzrokovati tjelesne ozljede i materijalne štete.  
Za točnu instalaciju i rukovanje pogledajte upute za instalaciju  
<https://www.schrack-seconet.com/de/services/downloadcenter> → B-HB-070  
Prije nego što počnete s instalacijom, pročitajte pažljivo sigurnosne napomene i pridržavajte ih se..



**NOTE**

Improper use or installation of the device can lead to injury or damages.  
For the exact procedure for proper installation and handling, please refer to the manufacturer documentation:  
<https://www.schrack-seconet.com/en/services/downloadcenter> → B-HB-070  
Please read this document carefully and follow the safety instructions before you begin with the installation.