

**IZJAVA O SVOJSTVIMA  
DECLARATION OF PERFORMANCE**

prema Uredbi o građevnim proizvodima (EU) br. 305/2011  
according to Construction Products Regulation (EU) No 305/2011

**Br. / No. CPR-20-13-019**

1. Jedinstvena identifikacijska oznaka vrste proizvoda: / *Unique identification code of the product-type:*

**BM-TMI** Ulazno/izlazni modul (vidi aneks)  
*Input/Output module (see annex)*

2. Namjena/namjene: / *Intended use/es:*

**sigurnost od požara / Fire safety**

3. Proizvođač: / *Manufacturer:*

**Schrack Seconet AG, Eibesbrunnergasse 18, 1120 Wien / Vienna, Österreich / Austria**

4. Ovlašteni predstavnik: / *Authorised representative:*

**nije primjenjivo / not applicable**

5. Sustav/sustavi za ocjenu i provjeru stalnosti svojstava (AVCP): / *System/s of AVCP:*

**1**

6a. Usklađena norma: / *Harmonised standard:*

**EN 54-18:2005/AC:2007** Sustavi za otkrivanje i dojavu požara – 18. dio: Ulazno/izlazni uređaji  
*Fire detection and fire alarm systems — Part 18: Input/output devices*

Prijavljeno tijelo/prijavljena tijela: / *Notified body/ies:*

**0786 VdS Schadenverhütung GmbH**

7. Objavljena svojstva: / *Declared performance/s:*

| Bitna obilježja   | Essential characteristics  | svojstva<br><i>Performance</i> | Usklađene tehničke specifikacije;<br>klauzula<br><i>Harmonised technical specification;<br/>Clause</i> |
|---|--|--------------------------------|--|
| Odgoda aktivacije (vrijeme aktivacije pri alarmu)       | Response delay<br>(response time to fire)                        | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.2  |
| Učinak u slučaju požara                                 | Performance under fire conditions                                | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.1.4  |
| Pogonska pouzdanost                                     | Operational reliability  | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.1.4  |
| Trajnost pogonske pouzdanosti, otpornost na temperaturu | Durability of operational reliability,<br>temperature resistance | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.3 – 5.4  |
| Trajnost pogonske pouzdanosti, otpornost na vibracije   | Durability of operational reliability,<br>vibration resistance   | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.8 – 5.11   |
| Trajnost pogonske pouzdanosti, otpornost na vlagu       | Durability of operational reliability,<br>humidity resistance    | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.5 – 5.6  |
| Trajnost pogonske pouzdanosti, otpornost na koroziju    | Durability of operational reliability,<br>corrosion resistance   | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.7  |
| Trajnost pogonske pouzdanosti, električna stabilnost    | Durability of operational reliability,<br>electrical stability   | položeno<br>pass               | EN 54-18:2005/AC:2007;<br>5.2, 5.12  |

8. Odgovarajuća tehnička dokumentacija i/ili specifična tehnička dokumentacija: /  
*Appropriate Technical Documentation and/or Specific Technical Documentation:*

**B-TD-BM-BSI-TMI-MCP1**

Prije utvrđeno svojstvo proizvoda u skladu je s objavljenim svojstvima.

Ova izjava o svojstvima izdaje se, u skladu s Uredbom (EU) br. 305/2011, pod isključivom odgovornošću prethodno utvrđenog proizvođača. /

*The performance of the product identified above is in conformity with the set of declared performance/s.*

*This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.*

Ova izjava o svojstvima je dostupna na internetu: / *This declaration of performance is available on the internet:*

[www.Schrack-Seconet.com/DoP](http://www.Schrack-Seconet.com/DoP)

Za proizvođača i u njegovo ime potpisao: / Signed for and on behalf by:


**Schrack Seconet AG**  
1120 Wien / Vienna, Österreich / Austria, 15.01.2018

ppa.



Thomas Kern  
Voditelj odjela za upravljanje proizvodima i kompetentnost  
Head of Product Management and Competence Center

ppa.



Heinrich Kohlenberger  
Voditelj odjela razvoja  
Head of Development

**Prilog  
Annex**

---

**Predmet izjave: / Object of the declaration:**

| <b>Broj artikla: / Item No:</b> | <b>Vrsta: / Type:</b> | <b>Opis:</b>          | <b>Description:</b> |
|---------------------------------|-----------------------|-----------------------|---------------------|
| 20-2600001-01                   | BM-TMI                | Ulazno/izlazni uređaj | Input/Output device |